



MONTGOMERY COUNTY BUILDING REGULATIONS

451 West Third Street
Dayton, Ohio 45422

(937) 225-4622
www.mcoho.org/build

TEMPORARY SERVICE RELEASE POLICY RESIDENTIAL

In order to facilitate construction progress of one, two and three family dwellings and their accessory structures, Montgomery County Building Regulations will authorize a Temporary Service Release (TSR) for electric power after the following items are approved:

1. Fault current compliance documents required.
 - A. If the service is rated over 200 amps, fault current information from DP&L must be submitted for review by this office before the TSR inspection is requested.
 - B. If DP&L indicates the fault current to the building is greater than 10,000 RMS a completed fault current analysis must also be submitted for review by this office before the TSR inspection is requested. Blank forms are available through the office of Montgomery County Building Regulations.

2. Rough/temporary service inspection required.
 - A. The main panel must be installed with proper cover.
 - B. At least one G.F.C.I. protected circuit to receptacles must be installed.
 - C. The electrical rough and service inspections must be completed.
 - D. Structure must be "Dried In" for the protection of electrical equipment

3. Building must be dried-in and secured.
 - A. Roof cover, either permanent or temporary such as shingles, felt paper or tarpaper, shall be installed and all openings in the roof must be covered to keep out moisture and water.
 - B. All exterior walls, gables, windows, doors and siding (or approved weather-resistant covering) shall be installed. In lieu of permanent windows and doors, exterior openings may be temporarily covered with plywood or equal.

Once the above requirements are completed and necessary inspections approved, the service will be released.

Revised RWM 03/15/2005